

County of Greenville Land Development Division 301 University Ridge, Ste. S-3300 Greenville, SC 29601 Larry Hendricks 864.467.4717 Tommy Lowe 864-467-4067 Jerry Pirkle 864-467-4781

## Single Family Residential LID-Self-Report Dry Well and Modified French Drain Maintenance Inspection Report

Any storm water management feature element shall be corrected, repaired, and/ replaced immediately. These deficiencies can affect the integrity of the efficienc the storm water management facility.	
Owner Contact Info:	
Inspector Name:	
Address:	
Property Owner:	
Inspection Date:	

\*For manufactured Dry Wells, see manufactures instructions for maintenance and repair of the system

BMP Element: BMP Deficiency:		Deficient: (x if Yes)	Comments:		
Main System	System is leaking or damaged.		If checked, make necessary repairs or replace system.		
	Water is flowing out of the overflow pipe during rainfall.		If checked, check for clogging/damage/ pump operation (if applicable). Ensure water fills up the device volume.		
	Piping system is damaged or broken.		If checked, make necessary repairs or replace system.		
	Trash, debris and/or sediment buildup.		If checked, remove trash. Try to identify source of sediment and debris and remove if possible.		
	Mosquito Proliferation.		If checked, make sure the tank lid is tightly fitting and the inlets and vents are either screened or tightly fitted. May choose to use mosquito control products that will not impact surface or ground water quality.		
	Presence of algae or floating aquatic vegetation.		If checked, clean out algae and/or floating aquatic vegetation. May use products labeled environmentally friendly specifically for cisterns and rain tanks to prevent regrowth.		
Captured Roof Area	Excessive overhanging vegetation/trees.		If checked, trim or remove vegetation/trees.		
	Excessive trash, debris, and/or sediment on rooftop.		If checked, remove trash. Check for source of debris and remove if possible.		
Gutter System	Gutters are clogged.		If checked, unclog gutters. Remove		

		trash, leaves and debris. Install gutter screens if necessary.		
	Rooftop runoff not reaching gutter system.	If checked, correct positioning or incorrect installation of gutters. May need to replace system.		
Overall	Unwanted / invasive vegetation, leaves, debris.	If checked, remove all unwanted / invasive vegetation, leaves and debris.		
	Facility is inaccessible.	If checked, redefine access path to feature. Remove any objects or obstacles blocking access. Ensure overflow is operating.		

Inspection should occur at least twice a year following a heavy storm event to determine if the feature is functioning.

Send by Mail:
Greenville County LDD
Atten: SFR Self Report
301 University Ridge, Suite S-3300
Greenville, S.C. 29601

Send by E-mail w/ Attachments: landdevelopment@greenvillecounty.org Subject: SFR Self Report

Comments:	 		 

<sup>\*</sup>Photo Documentation & Self Reporting-Take one photo of each feature following maintenance.

<sup>\*</sup>Send photo(s) annually, along with this inspection report to: