



STATIC = 140 PSI
FLOW = 1680 GPM

NOTE: ALL 6" VALVES OPEN RIGHT
FIRE HYDRANT TO BE 3-WAY & OPEN RIGHT
2" VALVE OPEN LEFT

Material List:

6" C.I. Pipe	-	550 LF
6" Valves	-	2
2" Valve	-	1
Fire Hydrant	-	1

James E. Dideroff, Jr., Paul B. Costner, Jr.
City Engineers

City Engineers of Public Works
of the City of Greenville, S. C.
March 10, 1977

PLAN BOOK NO. M12 1-1-5.3

MAPLE CREEK INDUS. PARK

DECEMBER, 1976 SCALE 1" = 400'

RECORDED **MAR 18 1977**

At 4:05 P.M.

21730

1000

4328 RV-2