



STATIC=115PSI
FLOW= 920GPM.

EXIS 2" B.O. VAL. TO BE
REMOVED

NOTE ALL 6" VALVES OPEN RIGHT.
ALL 2" VALVES OPEN LEFT.
ALL FIRE HYDRANTS TO BE
3-WAY & OPEN RIGHT.

BOLING RD. & BOLING CT.

FEB., 1976 SCALE 1" = 400'
REVISED FEBRUARY, 1978

Material List.

8" D. I. Pipe	-	590'
6" D. I. Pipe	-	1,460'
2" Galv. Pipe	-	880'
6" Valves	-	3
2" Valves	-	2
Fire Hydrants	-	2

Westminster Company, Inc.
to
Commissioners of Public Works
of the City of Greenville, S. C.
November 27, 1978

BLK. Book T34-1-5

RECORDED 'JAN 5 1979

19963

at 11:56 A.M.

4328 RV-2