



STATIC = 90 P.S.I.
RES. = 30 P.S.I.

STATIC = 100 P.S.I.
FLOW = 750 G.P.M.

NOTE: ALL 6" & 2" VALVES TO OPEN LEFT
ALL FIRE HYDRANTS TO BE 3-WAY
& OPEN LEFT

Material List:

6" D. I. Pipe	-	1,725' [±]
2" Galv. Pipe	-	700' [±]
6" Valves	-	2
2" Valves	-	4
Fire Hydrants	-	2

OAK FOREST, SEC. 3 & 4

MAY, 1979

SCALE 1" = 400'

Westminster Company
to
Commissioners of Public Works
of the City of Greenville, S. C.
September 27, 1979
(BLK. Book 547.1-1-20.2 & 22)

RECORDED OCT 29 1979 at 2:30 P.M.

14370

4328 RV.2