



BOOK 1116 PAGE 737

STA = 90 PSI

STATIC = 105 PSI
FLOW = 1300 GPM

NOTE: 6" & 8" VALVES TO OPEN RIGHT
FIRE HYDRANT TO BE 3-WAY
& OPEN RIGHT

<u>MATERIAL LIST:</u>	
8" D. I. Pipe	- 1,040'±
6" D. I. Pipe	- 15'±
8" Valve	- 1
6" Valve	- 1
Fire Hydrant	- 1

BEACON HILL, SEC. I
JULY, 1979 SCALE 1"=400'
REVISED NOV, 1979

Shoney's, Inc.
to
Commissioners of Public Works
of the City of Greenville, S. C.
November 15, 1979
Block Book 533.4-1-7.8

RECORDED DEC 3 1979 at 2:37 P.M.

18375

4328 RV-2