



VOL 1119 PAGE 201

020

NOTE: 6" & 12" VALS. OPEN RT.
 ALL 2" VALS. OPEN LT.
 FIRE HYDS. TO BE 3-WAY & OPEN RT.

The Fortis Corporation
 to
 Commissioners of Public Works
 of the City of Greenville, S. C.
 December 12, 1979
 (Pt. of BLK. BOOK 540.4-1-8.3)

MATERIAL LIST:

12" D. I. Pipe	-	430'
6" D. I. Pipe	-	2,065'
2" Galv. Pipe	-	230'
12" Valve	-	1
6" Valves	-	7
2" Valves	-	3
Fire Hydrants	-	3

PALMETTO DOWNS, SEC. II

MAR 1979 SCALE 1" = 400'
 REVISED JULY, 1979

RECORDED JAN 17 1980 at 3:54 P.M.

22256

4328 RV-2