



**NOTE: ALL 6" & 8" VALS. OPEN RT.
 2" VALS. OPEN LT.
 FIRE HYDS TO BE 3 WAY & OPEN RT.**

STATIC = 126 P.S.I.
 FLOW = 1300 G.P.M.

STATIC = 142 P.S.I.
 RES. = 125 P.S.I.

EASEMENT
 Paramount Builders, Inc. and
 Chanticleer Real Estate Company
 to

Commissioners of Public Works
 of the City of Greenville, **SOUTH EAST CHANTICLEER**
 S. C.

May 13, 1980
 Block Book WGI.4-1-1, 6, 7.1 & 8

MAY 1978

SCALE 1" = 400'

2836

Recorded July 31, 1980 at 11:11 A/M

5
0
0
9
5

4328 RV-2