



STATIC = 63 PSI
RES = 58 PSI

STATIC = 60 PSI
FLOW = 1140 GPM.

RECORDED MAY 8 1981
at 1:23 P.M.

NOTE ALL VALVES OPEN LEFT, FIRE HYDRANTS
TO BE 3-WAY & OPEN LEFT

BOOK 1147 PAGE 697

U. F. S. Service Corporation
to
Commissioners of Public Works
of the City of Greenville, S. C.
April 21, 1981
(BLK. BOOK # & 354-1-6.1)

MATERIAL LIST:

| | |
|---------------|---------|
| 8" D. I. Pipe | 1,660'± |
| 6" D. I. Pipe | 4,550'± |
| 2" Galv. Pipe | 1,020'± |
| 8" Valve | 1 |
| 6" Valves | 9 |
| 2" Valves | 4 |
| Fire Hydrants | 5 |

QUAIL RUN

OCT. 1980 · SCALE 1" = 400'

31256

4328 RV-2

0697