



STATIC = 35 P.S.I.  
RES. = 26 P.S.I.

STATIC = 40 P.S.I.  
FLOW = 920 G.P.M.

NOTE ALL 6" & 8" VALVES OPEN RIGHT, FIRE HYDRANTS TO BE 3-WAY & OPEN RIGHT.

(1650' ± TO PVT F. HYDT. ON 8" LINE, CONGAREE RD.)  
STATIC = 44 P.S.I.  
RES. = 40 P.S.I.

STATIC = 57 P.S.I.  
FLOW = 1185 G.P.M.

BY GWS UNDER REIMBURSEMENT AGREEMENT

*Mrs. Cleotha J. Pate*  
Easement  
~~to J.E. SIRRINE COMPANY~~  
to  
Commissioners of Public Works  
of the City of Greenville, S. C.  
May 27, 1981  
Block Book 543.1-1-1 & 2

*William F. Pate, Sr.*  
*William F. Pate, Jr.*

J.E. SIRRINE CO.  
DEC. 1980 SCALE: 1" = 400'  
REVISED MAR. 1981

RECORDED SEP 3 1981 at 10:18 A.M.

5940

4328 RV.2

0555