



STA. = 35 P.S.I.
RES. = 26 P.S.I.

STA. = 40 P.S.I.
FLOW = 920 G.P.M.

NOTE: 6" & 8" VALS. OPEN RIGHT
2" VALS. OPEN LEFT
FIRE HYD. TO BE 3-WAY & OPEN RIGHT

MATERIAL LIST:

8" D. I. Pipe	-	770'±
6" D. I. Pipe	-	16'±
2" Galv. Pipe	-	440'±
8" Valve	-	1
6" Valve	-	1
2" Valves	-	2
Fire Hydrant	-	1

ROPER AT PELHAM

DEC., 1981 SCALE 1"=400'
REVISED FEB., 1982

Alex & John Kiraikides
to
Commissioners of Public Works
of the City of Greenville, S. C.
May 14, 1982
Block Book 543.2-1-7

RECORDED JUN 15 1982 at 2:32 P.M.

28086

0 6 1 4

4328 RV-2