

South Carolina  
Department of  
Health and  
Environmental  
Control

EXHIBIT A

VCL 1189 PAGE 561

May 17, 1983

BOARD  
J. Lorin Mason, Jr., M.D., Chairman  
Gerald A. Kaynard, Vice-Chairman  
Leonard W. Douglas, M. D., Secretary  
Oren L. Brady, Jr.  
Moses H. Clarkson, Jr.  
Barbara P. Nuessle  
James A. Sprull, Jr.

COMMISSIONER  
Robert S. Jackson, M.D.  
2600 Bull Street  
Columbia, S.C. 29201

Mr. Merv C. Moeller  
Assistant General Manager  
Greenville Water System  
P. O. Box 687  
Greenville, S. C. 29602

Re: Frank A. Folk Properties  
Quad Apt. Complex - Buckhorn Road  
Greenville County

Dear Mr. Moeller:

Please accept this letter as acknowledgement of the February 9, 1983 agreement between Frank A. Folk and the Greenville Water System. This office recognizes that the water pressures in the surrounding areas and at Mr. Folk's property are not sufficient for adequate water service or fire protection. This fact has been taken under consideration during our review of plans and specifications submitted by O'Neil Engineering on behalf of Mr. Folk. Mr. Folk and/or his successor will be required to properly operate and maintain a booster pump and storage system of the size approved by this office to rectify this pressure situation. Failure to do so by Mr. Folk and/or his successor will be considered as a violation by Mr. Folk or his successor of his operating permit. Corrective action as necessary would be required of Mr. Folk and/or his successor by this Agency. By copy of this letter Mr. Folk is so notified of the above.

This letter should further serve as a release of Greenville Water System from this office's normal pressure requirements at this specific point of service. In explanation, the minimum pressure requirements at this customer's service connection as delineated by State Primary Drinking Water Regulations (R.61-58.4D.(3)) are waived. Maintaining the pressure requirements referenced above will be the responsibility of Mr. Folk and/or his successor and will be accomplished by an approved booster pump/storage system.

Should you have any questions concerning the above, please advise (758-5544).

Sincerely,

*M. K. Batavia*

M. K. Batavia, P. E., Director  
Water Supply Division

MKB:JAJ/hpj

cc: Mr. Frank A. Folk  
Mr. George Milam, Dist. Director

RECORDED JUN 3 1983 at 8:46 A.M.

32665

561

4328 (V-2)