



1189ms653

0
5
3

NOTE: 6" VALVES OPEN RIGHT, 2" VALVES OPEN LEFT, FIRE HYDRANT TO BE 3-WAY & OPEN RIGHT.

✓ *Balentine Builders*
 Ballentine Brothers Bldrs, Inc
 to
 Commissioners of Public Works
 of the City of Greenville, S.C
 May 16, 1983
 BLK. BOOK 541.1-1-14.1

STATIC = 95 P.S.I.
 FLOW = 1300 G.P.M.

STA. = 86 P.S.I.
 RES. = 74 P.S.I.

MATERIAL LIST:

6" D. I. Pipe	-	1,335'±
2" Galv. Pipe	-	270'±
6" Valves	-	2
2" Valves	-	2
Fire Hydrant	-	1
Valve Boxes	-	3

NORTHWOOD III
 NOV 1980 SCALE 1" = 400'
 REV. JUNE, 1981
 REV. FEB, 1983

32777

RECORDED JUN 3 1983 at 2:54 P.M.

4328-W-2