



NOTE: 6" & 8" VALS OPEN RIGHT
2" VALVE OPENS LEFT
FIRE HYDRANT TO BE
3-WAY & OPEN RIGHT

STATIC = 87 PSI
 FLOW = 1400 GPM

✓ GOLDEN OAKS PARK

SEPT 1983 SCALE: 1" = 400'
 EASEMENT
 Morris Construction Co., Inc.
 to
 Commissioners of Public Works
 of the City of Greenville, S. C.
 November 9, 1983
 BLK. BOOK 547.3-1-75 8

RECORDED: DEC 20 1983 at 3:21 P.M. 19604

4328-N-2