



STATIC = 116 PSI
 RES = 100 PSI
 FLOW = 1662 GPM

VOL 1211 PAGE 349

NOTE ALL VALVES OPEN RIGHT
 FIRE HYDRANT TO BE
 3-WAY & OPEN RIGHT

✓ ~~GREEN~~
 Greenville Ins. A Partnership
 Commissioners of Public Works
 of the City of Greenville, S. C.
 March 7, 1984
 B.P. 8748 533.2-1-18.4

BEST WESTERN AIRPORT INN
 MARCH, 1984 SCALE 1"=100'

RECORDED APR 27 1984 at 12:38 P/M

33632

1
 B
 4
 3
 0

74328 (W.2)