



NOTE SEE BRIDGES ROAD FOR PRESSURE & FLOW AT 20" MAIN.

PROPOSED 8" (UNDER REIMBURSEMENT AGREEMENT)

Rice Properties, Inc.
to
Commissioners of Public Works
of the City of Greenville, S. C.
November 11, 1983
APP. NO. 542.2-1-2.2

NOTE: 6" VALVES OPEN RIGHT
2" VALVES OPEN LEFT
FIRE HYDS. TO BE 3-WAY
& OPEN RIGHT

QUANTITY LIST:

6" D. I. Pipe	-	1800'
2" Galv. Pipe	-	1600'
6" Valves	-	1
2" Valves	-	9
Fire Hydrants	-	2
Valve Boxes	-	1

RICELAN CREEK
FEB, 1983 SCALE 1"=400'
REVISED AUG, 1983
106-11

RECORDED OCT 8 1984 at 9:31 A.M.