



STATIC = 87 PSI
 FLOW = 1400 GPM

VEL 1225 PISE 903

MATERIAL LIST:

8" D. I. Pipe	-	70'
6" D. I. Pipe	-	1,085'
2" Galv. Pipe	-	735'
8" Valve	-	1
6" Valves	-	4
2" Valves	-	6
Fire Hydrants	-	2
Valve Boxes	-	11

NOTE 8" 86" VALVES OPEN RIGHT
2" VALVES OPEN LEFT
FIRE HYDRANTS TO BE
3-WAY & OPEN RIGHT

Restinister Company, Inc.
 to
 Commissioners of Public Works
 of the City of Greenville, S. C.
 October 19, 1984
 Block Book 547.3-1-56

RECORDED NOV 8 - 1984 AT 10 05 9 AM

1-1066

WINDGATE SUBDIVISION SEC. I
 FEBRUARY, 1984 SCALE 1" = 400'
 REVISED OCTOBER, 1984

1225 PISE 903

1225 PISE 903