



STATIC = 110 PSI
RES = 80 PSI

STATIC = 110 PSI
FLOW = 1600 GPM

Material List:

8" D. I. Pipe	-	1,420'±
6" D. I. Pipe	-	15'±
2" Galv. Pipe	-	1,385'±
8" Valves	-	1
6" Valves	-	2
2" Valves	-	10
Fire Hydrants	-	2
Valve Boxes	-	13

✓ Prestige Builders of Greenville, Inc.
to
Commissioners of Public Works
of the City of Greenville, S. C.
November 2, 1984
Blk. Book M9.3-1-3

RECORDED NOV 21 1984
at 4:37 P.M.

15650

FORRESTER WOODS
SEC. VI, PH. II-A
OCT, 1984 SCALE 1"=400'

