



STA = 95 P.S.I.
RES = 65 P.S.I.

STA = 97 P.S.I.
FLOW = 1155 G.P.M.

NOTE: 6" VALVES OPEN RIGHT, 2" VALVES OPEN LEFT, FIRE HYD. TO BE 3-WAY & OPEN RIGHT.

MATERIAL LIST:

6" D. I. Pipe	-	980'±
2" Galv. Pipe	-	350'±
6" Valves	-	2
2" Valves	-	3
Fire Hydrant	-	1
Valve Boxes	-	5

DEERFIELD SEC. 2 & 3

SEPT, 1984 SCALE: 1" = 400'
 Mrs. Mae Belle Esco Fant
 &
 Mrs. Janice Fant Gilmore
 to
 Commissioners of Public Works
 of the City of Greenville, S. C.
 October 25, 1984
 BLK. BOOK 534.2-1-20

RECORDED DEC 5 1984 at 2:50 AM. 17022

