

BOILING SPRINGS FIRE DISTRICT VOL 1228 PAGE 375

2015 Hudson Rd. • Greer, S.C. 29651
268-7780

Board of Commissioners

John O. Long
Thomas M. Mitchell
Perry L. Hall
Roger H. Garst
G. Henry Watkins

Thomas E. Forrester, *Fire Chief*

November 23, 1982

Mr. Sam R. Putnam, Jr.
J.E. Sirrine Co.
Engineering - Architect Division
Post Office Box 5456
Greenville, South Carolina 29606

Dear Mr. Putnam:

This is to confirm that on November 22, 1982, we did review with you the plans for the Rollinggreen Village on Garlington Road. Due to the fact that you are planning on using Type VI construction, we ask that you provide us with a water system that will support fire flows of 3500 gpm for each building in the central core of apartments. Also, it is extremely important that fire partitions be installed properly -- tight, with no holes made in them, or, holes patched securely. We have seen a good deal of this type construction where this is not done and these voids in the partitions not only allow the fire to spread, they accelerate it. We also feel that access is very critical and agree with your plans to make the roads to County standards. If we may be of further assistance, let us know.

Sincerely,

Thomas E. Forrester

Thomas E. Forrester, Fire Chief

(CONTINUED ON NEXT PAGE)