

GREENVILLE SHERATONINVENTORY

February 28, 1984

Tool & Maintenance Area

refrig. gauges

Cuetis industries key machine

small step ladder (2 steps)

24" extension ladder new

1 8' step ladder

LAUNDRY

1 washer UniWash 50 lb (fair condition, needs door gaskets, approx 10 years old)

2 driers; bad condition, timers not functional, bearings bad, units approx 20 years old. Holes worn back of cabinet from friction.

Air handler for lobby and offices not operational. Compressor bad. Control units burned out. low voltage trans. burned out in a/c unit outside.

Bon warmer & steam kettle not operational. (bad controls)

Ice Machine under contract. (Merchants of Greenville 269-8770.)

Coffee Machine contract

No inventory in maintenance. By as needed. not able to supply parts. use own tools. have brought parts from home. posed pipe elect. parts, etc.

Approximately 18 window a/c units in rooms not operational. no parts.

Windows need caulking from outside. bad leaks